



# CERTIFICATE OF CONFORMITY

## *Product Conformity Scheme (PCS)-Type Test Certification*

Australian Certification Services Pty Ltd hereby certifies that a sample/s of the product/s as identified in the listing below and submitted by;

## Metal Manufactures Ltd

Trading as MM Kembla

30 Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA

Has been examined and found to be in conformity with the requirements of the Standard/s referred to below:

Evaluated to: AS 1530.3:1999 Methods for fire tests on building materials, components and structures Part 3: Simultaneous determination of ignitability, flame propagation, heat release and smoke release

Manufacturer: K Flex Malaysia Sdn Bhd

Product Type: Elastomeric Insulation

Product Description: Elastomeric Insulation (Black) Available in Coils Tubes and Sheets Suitable for Use for Solar Panels Low Pressure Steam or Industrial Processes up to 150°C

Brand: K Flex HT Solar

Temperature Range: -50°C to 150°C

Thermal Resistance: Ignitability Index (0) Spread of Flame Index (0) Heat Evolved Index (0) Smoke Developed Index (5)

Test Report Identification: AWTA Product Testing (NATA 983/985/1356) Test Report Number 17-000512 date 21/02/2017 (10mm Sheet) AS/NZS 1530.3:1999

The Type Test Certificate Holder shall comply with the rules and procedures of the Product Conformity Scheme for those products manufactured identically to the sample/s examined conforming to the Standard.

Paul Greig  
General Manager

Issue Date: 24<sup>th</sup> November 2017  
Initial Issue Date: 30<sup>th</sup> March 2015  
Expiry Date: 29<sup>th</sup> March 2020

Certificate No.: 4024

This certificate remains the property of Australian Certification Services Pty Ltd.

The Product Conformity Scheme (PCS)-Type Test Certification is a conformity assessment scheme based on ISO Guide 67 (system 1b)

