

Certificate of Conformity

Product Conformity Scheme (PCS)-Type Test Certification

Australian Certification Services Pty Ltd hereby certifies that a sample of the products as identified in the listing below and submitted by;

Metal Manufactures Ltd

Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA

Has been examined and found to be in conformity with the requirements of the Standard/s referred to below;

Evaluated to: AS/NZS 4859.1:2002 Materials for the thermal insulation of buildings Part 1:
General criteria and technical provisions

Manufacturer: K Flex Malaysia Sdn Bhd

Product Type: Elastomeric Insulation

Brand: K Flex HT Solar

Product Description: Elastomeric Insulation (Black) Available in Coils Tubes and Sheets Suitable for
Use for Solar Panels Low Pressure Steam or Industrial Processes up to 150°C

Temperature Range: -50°C to 150°C

Thermal Resistance: 0.4 m²K/W

Test Report Identification: AWTA Product Testing (NATA 983/985/1356) Test Report Number 14-002112
date 27/2/2015 (13mm Pipe Insulation) ASTM C518-2010



Issue Date 25th November 2015
Initial Issue Date: 30th March 2015
Expiry Date: 29th March 2020

Paul Greig
General Manager

Certificate No.: 4023

This certificate remains the property of Australian Certification Services Pty Ltd

The Product Conformity Scheme (PCS)-Type Test Certification is a conformity assessment scheme based on ISO Guide 67 (system 1b)

