

Certificate of Conformity

Product Conformity Scheme (PCS)-Type Test Certification

Australian Certification Services Pty Ltd hereby certifies that a sample of the products as identified in the listing below and submitted by;

Metal Manufactures Ltd

Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA

Has been examined and found to be in conformity with the requirements of the Standard/s referred to below;

Evaluated to: AS/NZS 4859.1:2002 Materials for the thermal insulation of buildings Part 1: General criteria and technical provisions

Manufacturer: K Flex Malaysia Sdn Bhd

Product Type: Elastomeric Insulation

Brand: K Flex ST

Product Description: Elastomeric Insulation (Black) Available in Tubes Pre Cut with Adhesive and Sheets Suitable for Use for all Applications Civil and Industrial that Require use of Insulation Material

Temperature Range: -40°C to 85°C

Thermal Resistance: 0.4 m²K/W

Test Report Identification: AWTA Product Testing (NATA 983/985/1356) Test Report Number 14-001840 date 18/12/2014 (13mm Sheet Insulation) ASTM C518-2010



Issue Date: 25th November 2015
Initial Issue Date: 30th March 2015
Expiry Date: 29th March 2020

Paul Greig
General Manager

Certificate No.: 4022

This certificate remains the property of Australian Certification Services Pty Ltd
The Product Conformity Scheme (PCS)-Type Test Certification is a conformity assessment scheme based on ISO Guide 67 (system 1b)

