



# CERTIFICATE OF CONFORMITY

## *Product Conformity Scheme (PCS)-Type Test Certification*

Australian Certification Services Pty Ltd hereby certifies that a sample/s of the product/s as identified in the listing below and submitted by;

### **Metal Manufactures Ltd**

Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA

Has been examined and found to be in conformity with the requirements of the Standard/s referred to below:

Evaluated to: AS/NZS 4859.1:2018 Thermal insulation materials for buildings Part 1: General criteria and technical provisions

Manufacturer: K Flex Malaysia Sdn Bhd

Product Type: Elastomeric Insulation

Brand: K Flex ST

Product Description: Elastomeric Insulation (Black Nitrile) Available in Tubes Pre Cut with Adhesive and Sheets Suitable for Use for all Applications Civil and Industrial that Require use of Insulation Material

Temperature Range: -40°C to 85°C

Thermal Resistance: 0.4 m<sup>2</sup>K/W

Test Report Identification: AWTA Product Testing (NATA 983/985/1356) Test Report Number 14-001840

The Type Test Certificate Holder shall comply with the rules and procedures of the Product Conformity Scheme for those products manufactured identically to the sample/s examined conforming to the Standard.

Paul Greig  
General Manager

Issue Date: 7<sup>th</sup> July 2021  
Initial Issue Date: 30<sup>th</sup> March 2020  
Expiry Date: 29<sup>th</sup> March 2025

Certificate No.: 4022

This certificate remains the property of Australian Certification Services Pty Ltd.

The Product Conformity Scheme (PCS)-Type Test Certification is a conformity assessment scheme based on ISO 17067 (Scheme Type 1a)

