

CERTIFICATE OF CONFORMITY

Intertek SAI Global hereby grants:

MM Kembla

30 Gloucester Boulevard, Port Kembla, NSW, 2505, Australia

Product Safety Type Test Licence

Evaluated to:

**AS/NZS 4020:2018 - Testing of products for use in contact
with drinking water**

The Type Test Licensee the right to use the Type Test Certification Trade Mark, as shown below, to those goods manufactured identically to the sample examined conforming to the Standard to Specification above

**Certificate No:
PTT40014**

Originally Certified:
28 November 2013

Current Certification:
13 November 2025

Issued:
21 November 2025

Expires:
27 November 2028



Type Tested



Rathin Grover
President, Business Assurance

SAI Global Certification Services Pty.
Ltd.
Level 7 Suite 7.01 45 Clarence Street
Sydney NSW 2000 Australia



ATTACHMENT TO CERTIFICATE OF CONFORMITY

SAI Global hereby grants:

MM Kembla

30 Gloucester Boulevard, Port Kembla, NSW, 2505, Australia

Product Safety Type Test Licence

Evaluated to:

AS/NZS 4020:2018 - Testing of products for use in contact with drinking water

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Scaling Factor	Maximum Holding Water Temperature (°C)	Date Endorsed
DN15A	Bendable Copper Tube	MM Kembla	Bendable Copper tube 12.70 x 1.02	Bendable Copper Tube	Copper	In-the-product exposure (380,950 mm²/L)	95	13 Nov 2025
DN15A	Bendable Copper Tube	MM Kembla	Bendable Copper Tube 12.70 x 1.02	Bendable Copper Tube	Copper	In-the-product exposure (380,950 mm²/L)	95	25 Nov 2022
DN25A	Hard Drawn Copper Tube	MM Kembla	Hard Drawn Copper Tube 25.40 x 1.63	Hard Drawn Copper Tube	Copper	In-the-product exposure (177,780 mm²/L).	95	25 Nov 2022
DN25A	Hard Drawn Copper Tube	MM Kembla	Hard Drawn Copper Tube 25.40 x 1.63	Hard Drawn Copper Tube	Copper	In-the-product exposure (177,780 mm²/L)	95	25 Nov 2022

End of Record

Certificate No: PTT40014

Issued Date: 21 November 2025

This schedule supersedes all previously issued schedules

