



## Product Conformity Scheme (PCS)-Type Test Certification

# Certificate of Conformity

Pro-Switch Pty Ltd hereby certifies that the products as identified on the Product Certification Schedule and submitted by;

## Metal Manufactures Ltd

Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA

Have been examined and found to be in conformity with the requirements of the Standard/s referred to below as from time to time amended;

Product Type: Elastomeric Insulation  
Evaluated to: AS/NZS 4859.1:2018 Thermal insulation materials for buildings Part 1: General criteria and technical provisions  
Brand: K Flex HT Solar  
Manufacturer: K Flex Malaysia Sdn Bhd  
Test Report Reference: AWTA Product Testing (NATA 983/985/1356) Test Report Number 14-002112  
Conditions or Limitations: To be installed in accordance with the National Construction Code (NCC)

Issue Date: 29<sup>th</sup> March 2025  
Initial Issue Date: 30<sup>th</sup> March 2015  
Expiry Date: 29<sup>th</sup> March 2030

Simon Clarke  
General Manager

### Certificate No.: 4023

This certificate remains the property of Pro-Switch Pty Ltd

The Product Conformity Scheme (PCS)-Type Test Certification is a conformity assessment scheme based on ISO 17067 (Scheme Type 1a)



Pro-Switch Pty Ltd  
ABN 37 121 022 366  
PO Box 3082  
Norman Park QLD 4170  
Australia  
Phone: +61 408 704 809  
Email: info@pro-switch.com.au  
www.pro-switch.com.au



Certificate Number: 4023  
Issue Date: 29/03/2025  
Issue: CR04



## Product Conformity Scheme (PCS) - TT Certification Licence Schedule

<b>Certificate Holder</b>	Metal Manufactures Ltd ABN: 13 003 762 641
<b>Certificate Holder Address</b>	Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA
<b>Certificate Number</b>	4023
<b>Certification Standard</b>	AS/NZS 4859.1:2018 Thermal insulation materials for buildings Part 1: General criteria and technical provisions

### Product Listing

<b>Model ID</b>	<b>Product Description</b>	<b>Temperature Range</b>	<b>Thermal Conductivity</b>
K Flex HT Solar	Elastomeric Insulation (Black) Available in Coils Tubes and Sheets Suitable for Use for Solar Panels Low Pressure Steam or Industrial Processes up to 150°C	-50°C to 150°C	0.0422 W/m.K



Pro-Switch Pty Ltd  
ABN 37 121 022 366  
PO Box 3082  
Norman Park QLD 4170  
Australia  
Phone: +61 408 704 809  
Email: [info@pro-switch.com.au](mailto:info@pro-switch.com.au)  
[www.pro-switch.com.au](http://www.pro-switch.com.au)



Certificate Number: 4023  
Issue Date: 29/03/2025  
Issue: CR04